



NOTES:

1. WHEN FOUNDATION WALLS ARE CONSTRUCTED OF CONCRETE BLOCK (CMU), MM6125 MUST BE INSTALLED IN FABRIC REINFORCED MEMBRANE ASSEMBLY.
2. WHEN THE FACE OF THE FOOTING IS NOT ACCESSIBLE, A 1/2" X 1/2" SHOULD BE CUT/FORMED INTO THE FOOTING TO PROVIDE A POTENTIAL WATER STOP FOR THE MEMBRANE.



**Monolithic
Membrane
6125-FR**
WATERPROOFING SYSTEMS

AMERICAN HYDROTECH, INC.

**TYPICAL FOUNDATION WALL
DETAILING AT FOOTING**

SCALE: NONE
DATE: 11/01/17

W-12C